NINETECH
INFRA SOLUTIONS PVT LTD

REG No. CBS/C1/CIVIL/6551/2015

Email Id: info ninetechinfra@gmail.com

Corp. Off: #14, 3rd Floor, Hithaa complex, 80 feet Ring Road (Kengeri),
Nagadevanahalli, BENGALURU – 560 056, Karnataka

NT/QC/110V-Y6/2022-23

Date: 27-07-2022

To,
The Executive Engineer,
Yelahanka Division
Bangalore.

"FREQUENCY AND QUALITY REPORT"

Dear Sir,

Subject: Regarding Quality Report for the below mentioned work.

Name of Work:Restoration and Improvements of Balance Roads Ananthapura village, Prakruthi layout, Nisarga layout and surrounding areas in ward no-03 of Yelahanka New town Sub division

Item No	Description of work	Unit	Qty	No of Samples Tested	Frequency	Results Standards
1	Providing and Constructing dry lean cement concrete mix CC 1:5:10 base with OPC 25mm and down size graded granite metal coarse aggregate at 0.86cum and	Cum	377.81	4	Per 100 cum	Meets Morth V Revision Standards
2	Constructing un-reinforced, plain cement concrete for pavements using Grade concrete M30 over a prepared base with OPC at 360 kg/cum and coarse aggregate	Cum	377.81	8	Per 50 cum	Meets Morth V Revision Standards
	Construction of granular sub-base Grading V as Sub-base and drainage layer by providing coarse graded crushed stone aggregates of granite/ trap/basalt	Cum	949.84	3	Per 400 cum	Meets Morth V Revision Standards
3	Providing, laying, spreading and compacting cushed stone aggregates of granite / trap / basalt to wet mix macadam specifications including pre mixing the	Cum	1266.46	7	Per 200 cum	Meets Morth V Revision Standards
4	Providing and laying dense graded bituminous macadam using crushed aggregates of specified grading; premixed with VG30 grade bituminous binder and,	Cum	665.87	7	Per 100 cum	Meets Morth V Revision Standards

AE

NINETECH
INFRA SOLUTIONS PVT LTD

Email Id: info.ninetechinfra@gmail.com

REG No. CBS/C1/CIVIL/6551/2015

Corp. Off: #14, 3rd Floor, Hithaa complex, 80 feet Ring Road (Kengeri),
Nagadevanahalli, BENGALURU – 560 056, Karnataka

Item No	Description of work	Unit	Qty	No of Samples Tested	Frequency	Results Standards
5	Providing and laying bituminous concrete using crushed aggregates of specified grading, premixed with bituminous binder and filler, transporting the hot mix to work	Cum	532.70	6	Per 100 cum	Meets Morth V Revision Standards

With respect to the above subject & name of the work, we have inspected the work and the Quantity and Quality of above mentioned items of the work was found to be completed satisfactorily for the 2nd and Final bill. The all the samples satisfies the standards requirements as per MORTH V Revision 2013.

Thanking you,

With Regards,

For Ninetech Infra Solutions Pvt Ltd

AE